

(UK)



Titon

894 The Crescent
Colchester Business Park
Colchester
Essex
CO4 9YQ

HRV1.35 Q+ Eco HMB C (Enthalpy) **CHECK FW No
WITH DEVELOPS*

TP408HMBE

B ()
A+ ()
E ()

70%

237m³/h

61.50W

49dB

0.0461m³/s

50Pa

SPI

0.3709W/(m³/h)

0.85 *

5%

5%

AEC

AHS

kWh/(m².a)	-65.8	-32.0	-10.1
kWh/a	9.2	3.8	3.4
kWh	80.0	40.9	18.5

Auralite,

/

www.titon.com

*