

(BG)



Titon

894 The Crescent
Colchester Business Park
Colchester
Essex
CO4 9YQ

HRV1.35 Q+ Eco aura C (Enthalpy)

TP418BE/LH

SEC A ()

SEC A + ()

SEC E ()

—

70%

237m³/h

61.90W

49dB

0.0461m³/s

50Pa

SPI

0.3734W/(m³/h)

0.65 *

5%

5%

SEC	kWh/(m ² .a)	-72.9	-37.4	-14.4
AEC	kWh/a	7.8	2.4	2.0
AHS	kWh	83.7	42.8	19.4

Aurastat/Auramode

/

www.titon.com

*

0-10V