

# Product Fiche (EN-GB)



<b>Supplier Name</b>	Titon			
<b>Supplier Address</b>	Peartree Road Stanway Colchester Essex CO3 0JL			
<b>Model</b>	CME2 Q PLUS HA (Humidity) 2ND FIX UNIT			
<b>Model Identifier</b>	TP303HA			
<b>Specific Energy Consumption Class</b>	SEC Class E (Average Climate) SEC Class A (Cold Climate) SEC Class F (Warm Climate)			
<b>Declared Typology</b>	UniDirectional			
<b>Type Of Drive Installed</b>	Variable Speed Drive			
<b>Type Of Heat Recovery System</b>	None			
<b>Thermal efficiency of heat recovery</b>	0%			
<b>Maximum flow rate</b>	437m <sup>3</sup> /h			
<b>Effective Power Input</b>	26.40W			
<b>Sound Power Level</b>	55dB			
<b>Reference Flow Rate</b>	0.0850m <sup>3</sup> /s			
<b>Reference Pressure Difference</b>	50Pa			
<b>SPI</b>	0.0864W/(m <sup>3</sup> /h)			
<b>Ventilation Control Factor</b>	0.85 *			
<b>Declared Maximum Internal Leakage Rate</b>	0%			
<b>Declared Maximum External Leakage Rate</b>	10%			
		<b>Cold Climate</b>	<b>Average Climate</b>	<b>Warm Climate</b>
<b>SEC</b>	<b>kWh/(m<sup>2</sup>.a)</b>	-40.9	-20.0	-8.0
<b>AEC Annual Electricity Consumption</b>	<b>kWh/a</b>	0.8	0.8	0.8
<b>AHS Annual Heating Saved</b>	<b>kWh</b>	42.9	21.9	9.9
<b>Installation Requirements</b>	Regulated supply/exhaust grilles (for example, background ventilators) must be installed in the façade for natural air supply/extraction.			
<b>Pre/dis-assembly instructions</b>	<a href="http://www.titon.co.uk">www.titon.co.uk</a>			

\* Using the internal humidity sensor to provide central demand control