

## DECLARATION OF PERFORMANCE

According to Annex III of Regulation (EU) Nr. 305/2011 (Construction Products Regulation)


### QUELFIRE QRS – FIRE SLEEVES

1. **Unique identification code of the product-type:**  
Quelfire QRS Fire Sleeves
2. **Type, batch or serial number as required pursuant to Article 11(4):**  
See batch number displayed on the product
3. **Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification:**  
Fire stopping and sealing Product for Penetration Seals, see ETA 20/1206  


Pipe penetrations	Plastic pipes	<b>The field of application has to comply with the content of the related ETA 20/1206</b>
-------------------	---------------	---
4. **Name, registered trade name or registered trademark and contact address as required pursuant to Article 11(5):**  
Quelfire Ltd, Unit 3, Millbuck Way, Springvale Industrial Estate, Sandbach, Cheshire, CW11 3HT,  
Tel: 0161 928 7308, Email: [sales@quelfire.co.uk](mailto:sales@quelfire.co.uk)
5. **Authorised representative:**  
Certification Company B.V.  
Veluwezoom 42 1327 AH Almere The Netherlands  
[admin@certification-company.com](mailto:admin@certification-company.com)
6. **System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:**  
System 1
7. **Harmonised standard:** n.a.
8. **In the case of the declaration of performance concerning product covered by a Harmonised Standard and/or ETA:** Warrington Certification Ltd issued ETA Number 20/1206 on the basis of Guideline for European Technical Approval of Fire Stopping and Fire Sealing Products: EAD 350454-00-1104 Issue September 2017 performed initial and continuous surveillance of the place of manufacture and the factory production control implemented, sampled product and witnessed initial type testing under system 1.  
  
UL international UK Ltd have performed surveillance of the place of manufacture and the factory production control implemented issued the Certificate of Constancy of Performance 2821-CPR-0262
9. **Declared performance:**  

Essential Characteristic	Declared performance/Harmonised technical specification
<b>Reaction to fire</b>	Class F according to EN 13501-1, see ETA 20/1206 Clause 3.1.1
<b>Resistance to fire</b>	Resistance to fire performance and field application in accordance with EN 13501-2, see ETA 20/1206 Clause 3.1.2
<b>Dangerous substances</b>	See ETA 20/1206 Clause 3.2.1
<b>Durability and serviceability</b>	Type: X intended for use in conditions exposed to weathering in accordance with EAD 350454-00-1104, EOTA Technical Report – TR024 see ETA 20/1206 Clause 3.3.1
<b>Other</b>	Not applicable/No performance determined
10. **The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.**

Signed for and on behalf of the manufacturer.



Keith Wells  
Managing Director  
Quelfire Ltd



Darryl Wells  
Product Development  
Quelfire Ltd